

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 52

Dated: 31/2/24

It is certified that an inspection team headed by Nehraj
(Name of Officers with designation) from Assistant Engineer
(Name of Department/ Office) inspected the P.H. Sub-Division, Sasaram
(Name & Address of the school) on 09/02/24 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. The above is valid for a period of 08/02/2025

Signature with Seal:

Name :

Designation :

Assistant Engineer of Public Health Department
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

To

Name & Address of the Office / Department : PHED

Oxford Convent School
Hawachich, Hathani Mor
Nokha (Rehta)
(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Office of the Executive Engineer

Public Health Engineering Department, Sasaram (Rohtas)

Divisional Laboratory:- Sasaram

(Values in mg /lit. except pH. Otherwise mentioned)

a :- Patna		Division Name: SASARAM										Date:10/02/2024								
Sl. No.	Block	Panchayat	Village	Name of Habitation/ Ward No.	Location of Source	Parameters														
						pH	Turb.	Ec	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO3	SO4	F	AS	Total Coll.
	Nokha	Hathani	Nawadiah, hathani, Mor	Oxford Convent School	Oxford Convent School	7.3	0.5	430	280	206	64	34.08	40	180	0.1	BDL	10	0.7	NT	Negative
Desirable Limit						6.5-8.5	1		500	200	75.0	30.00	250	200	1.0	45	200	1	0.01	
Drinking Water Specification (Second Revision) IS 10500 /2012 Permissible limit in absence of alternate source						NR	5.0 NTU		2000	600	200	100	1000	600	NR	NR	400	1.5	NR	

- BDL (Below Detection Limit), NT (Not Tested) & NR (NO Relaxation)

- Sample collected by - School Staff

Asst. Chemist
10-02-2024
Asst. Chemist

P.H. Div, Sasaram

Chemist
10/02/2024
Chemist
P.H. Div, Sasaram